

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : *615769*

Date Reported: *12/02/16*

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : *"VAKF1"*

Sampled By : *RRB of BSPS*

Sample Date : *11/12/16*

Sample Time : *0844*

Date Received *11/17/16*

Sample Type : *SDWA*

KAR Sample No. : *615769-07*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep. metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>11/21/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>0.52</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=0.015 mg/L</i>

KAR Laboratories, Inc. . . .

Attest: *David R. Decker*
LABORATORY MANAGER

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : **615769**

Date Reported: **12/02/16**

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : **"VAWC"**

Sampled By : *RRB of BSPS*

Sample Date : *11/12/16*

Sample Time : *0845*

Date Received **11/17/16**

Sample Type : **SDWA**

KAR Sample No. : **615769-08**

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep, metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>11/21/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>0.61</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL=0.015 mg/L</i>

KAR Laboratories, Inc. . . .

Attest: *David R. Decker*
Laboratory Manager

LABORATORY DETAIL REPORT

Client: *Berrien Springs Public Schools*

KAR Project No. : *615769*

Date Reported: *12/02/16*

Project

Description : *Analysis of drinking water for lead and copper.*

Sample ID : *"VAKF2"*

Sampled By : *RRB of BSPS*

Sample Date : *11/12/16*

Sample Time : *0846*

Date Received *11/17/16*

Sample Type : *SDWA*

KAR Sample No. : *615769-09*

Test	Result	Units of Measure	Method	Analyzed	Analyst	Comments
<i>Prep. metals</i>	<i><1</i>	<i>NTU</i>	<i>EPA 200.7/8</i>	<i>11/21/16</i>	<i>MID</i>	
<i>Copper, total</i>	<i>0.55</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=1.3 mg/L</i>
<i>Lead, total</i>	<i><0.001</i>	<i>mg/L</i>	<i>EPA 200.8</i>	<i>11/30/16</i>	<i>NHM</i>	<i>MCL*=0.015 mg/L</i>

KAR Laboratories, Inc.

Attest: 
LABORATORY DETAIL REPORT